

## **Addendum No. 4**

**J C Roe Center  
Murrayville Elementary School  
Walter Parsley Elementary School  
Modular Classrooms**

**January 17, 2018**

### **Attachments:**

**List of contractors for Fire, Security and Technology.**

### **Additions and Clarifications:**

- 1. Based on questions from several bidders we are providing the attached list of contractors who have provided services to the school for fire, security and technology.**
- 2. As a follow up to the question concerning the interior wall height; The specification for the modular classroom states that the wall will extend to the truss bearing height. This is typically 8-feet above the finished floor. Since we do not yet have shop drawings for the new modular classrooms, bidders should assume an interior wall height of 9-feet above the finished floor.**

**END OF ADDENDUM**

**THERE ARE A TOTAL OF TWO (2) PAGES IN THIS ADDENDUM.**  
~~Please confirm the receipt of this addendum~~

## **Fire, Security and Technology Contractors**

**Murrayville Elementary School  
Walter Parsley Elementary School  
Modular Classrooms**

**January 17, 2018**

### **Fire**

1. Keller's, Inc. – (910) 392-7011 [[currently working for NHCS](#)]
2. Mark Systems, Inc. – (910) 794-3111

### **Security**

1. American Detection Systems, Inc. – (910) 799-7172 [[currently working for NHCS](#)]
2. Keller's, Inc. – (910) 392-7011
3. Port City Sound & Security – (910) 790-5700
4. Interconnect Products & Services – (910) 452-9499

### **Technology**

1. Interconnect Products & Services – (910) 452-9499
2. MTS Service – (910) 762-3700

These are the contractors that are working or have previously worked on projects for NHCS.

All work done on the Fire Alarm will need to be coordinated through Keller's, Inc.